

POLAND CSD BUSINESS OFFICE

2020 Lead Water Testing Update

Following the 2020 NYS Compliance Water Testing the drinking water at Poland Central School District continues to be safe. No Drinking fountains or potable water sources have tested positive for lead.

26 outlets that are not used for drinking did show signs of lead. 21 of these outlets are science and art lab sinks. Lab faucets are more susceptible to lead because of their heavy industrial construction. 4 sinks in our older bathrooms and 1 in our library office also tested positive. These outlets were all discovered in our 2016 testing. Following is an update on the status of the Lead Remediation Activities at Poland Central School:

Location	Status
Misc. Bathroom Sinks	4 Sinks in our older bathrooms are labeled Non-Potable. Plumbing will be replaced in a Future Capital Project.
High School Art Lab Sinks	3 Sinks are labeled Non-Potable. Plumbing will be replaced in a Future Capital Project.
MS & HS Science Lab Sinks	18 Sinks are labeled Non-Potable. Plumbing will be replaced in a Future Capital Project.
Library Office Sink	1 Sink is labeled Non-Potable. Plumbing will be replaced in a Future Capital Project.

All outlets that are to be kept in service will be labeled as non-potable until they are shown to be below the NYS Action Level of 15 parts per billion, according to a report from a New York State ELAP-certified laboratory.

Chad Hess
School Business Official/
Director of Facilities

Chad Hess – School Business Official
74 Cold Brook Street
Telephone (315) 826-0204



Email: chess@polandcsd.org
Poland, New York 13431
Fax (315) 826-7516