



July 22, 2025

Danielle Roark
HFHO BOCES Poland Central School District
74 Cold Brook St.
Poland, NY 13431

RE: Project: 08215494 7/6
Pace Project No.: 70367053

Dear Danielle Roark:

Enclosed are the analytical results for sample(s) received by the laboratory on July 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script, reading 'Michelle Cohen'.

Michelle Cohen
michelle.cohen@pacelabs.com
516-370-6000
Project Manager

Enclosures

cc: HFGO BOCES Safety Services, HFHO BOCES Poland
Central School District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: 08215494 7/6

Pace Project No.: 70367053

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 1-93 SINK		Lab ID: 70367053001		Collected: 07/10/25 09:40		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		07/17/25 22:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6
Pace Project No.: 70367053

Sample: 2- BOYS LOCKER ROOM		Lab ID: 70367053002	Collected: 07/10/25 09:42	Received: 07/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		07/17/25 22:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 3- BOYS LOCKER ROOM		Lab ID: 70367053003	Collected: 07/10/25 09:45	Received: 07/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.0	ug/L	1.0	1		07/17/25 22:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 4- GIRLS LOCKER ROOM		Lab ID: 70367053004		Collected: 07/10/25 09:46		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.2	ug/L	1.0	1		07/17/25 22:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 5-GIRLS LOCKER ROOM		Lab ID: 70367053005		Collected: 07/10/25 09:48		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		07/17/25 22:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 6-86		Lab ID: 70367053006		Collected: 07/10/25 09:49		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/17/25 22:50	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 7- 86		Lab ID: 70367053007		Collected: 07/10/25 09:50		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/17/25 22:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 8- 84		Lab ID: 70367053008		Collected: 07/10/25 09:51		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		07/17/25 22:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6
Pace Project No.: 70367053

Sample: 9-87		Lab ID: 70367053009		Collected: 07/10/25 09:52		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/17/25 22:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: 08215494 7/6
Pace Project No.: 70367053

Sample: 10- 2		Lab ID: 70367053010		Collected: 07/10/25 09:54		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	24.2	ug/L	1.0	1		07/17/25 22:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 11 - 2		Lab ID: 70367053011		Collected: 07/10/25 09:55		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	22.4	ug/L	1.0	1		07/17/25 22:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6
Pace Project No.: 70367053

Sample: 12- 2		Lab ID: 70367053012		Collected: 07/10/25 09:57		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	22.4	ug/L	1.0	1		07/21/25 16:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 13- 2		Lab ID: 70367053013		Collected: 07/10/25 09:58		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	26.6	ug/L	1.0	1		07/21/25 16:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 14- 44		Lab ID: 70367053014		Collected: 07/10/25 09:59		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		07/21/25 16:51	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: 08215494 7/6

Pace Project No.: 70367053

Sample: 15 - 44		Lab ID: 70367053015		Collected: 07/10/25 10:00		Received: 07/15/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		07/21/25 16:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: 08215494 7/6

Pace Project No.: 70367053

QC Batch:	409721	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70367053001, 70367053002, 70367053003, 70367053004, 70367053005, 70367053006, 70367053007, 70367053008, 70367053009, 70367053010, 70367053011		

METHOD BLANK:	2172250	Matrix:	Water
Associated Lab Samples:	70367053001, 70367053002, 70367053003, 70367053004, 70367053005, 70367053006, 70367053007, 70367053008, 70367053009, 70367053010, 70367053011		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/17/25 22:18	

LABORATORY CONTROL SAMPLE:	2172251					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.0	104	85-115	

MATRIX SPIKE SAMPLE:		2172253					
		70367189002	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	53.5	107	70-130	

MATRIX SPIKE SAMPLE:		2172255					
		70367189003	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	58.6	117	70-130	

SAMPLE DUPLICATE:	2172252				
Parameter	Units	70367189002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	2172254				
Parameter	Units	70367189003 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: 08215494 7/6

Pace Project No.: 70367053

QC Batch: 410075

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70367053012, 70367053013, 70367053014, 70367053015

METHOD BLANK: 2174551

Matrix: Water

Associated Lab Samples: 70367053012, 70367053013, 70367053014, 70367053015

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	07/21/25 16:11	

LABORATORY CONTROL SAMPLE: 2174552

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE: 2174554

Parameter	Units	70367477012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	58.9	118	70-130	

MATRIX SPIKE SAMPLE: 2174556

Parameter	Units	70367477013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	55.9	110	70-130	

SAMPLE DUPLICATE: 2174553

Parameter	Units	70367477012 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 2174555

Parameter	Units	70367477013 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: 08215494 7/6
Pace Project No.: 70367053

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 08215494 7/6

Pace Project No.: 70367053

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70367053001	1-93 SINK	EPA 200.8	409721		
70367053002	2- BOYS LOCKER ROOM	EPA 200.8	409721		
70367053003	3- BOYS LOCKER ROOM	EPA 200.8	409721		
70367053004	4- GIRLS LOCKER ROOM	EPA 200.8	409721		
70367053005	5-GIRLS LOCKER ROOM	EPA 200.8	409721		
70367053006	6-86	EPA 200.8	409721		
70367053007	7- 86	EPA 200.8	409721		
70367053008	8- 84	EPA 200.8	409721		
70367053009	9-87	EPA 200.8	409721		
70367053010	10- 2	EPA 200.8	409721		
70367053011	11 - 2	EPA 200.8	409721		
70367053012	12- 2	EPA 200.8	410075		
70367053013	13- 2	EPA 200.8	410075		
70367053014	14- 44	EPA 200.8	410075		
70367053015	15 - 44	EPA 200.8	410075		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace 2012

Pace® Location Requested (City/State):

Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: **HFHO BOCES, Poland CSD**
Street Address: **74 Cold Brook Street, Poland NY 13431**

Contact/Report To: **John D. Strickland**
Phone #: **(315) 826-0245**
E-Mail: jstrickland@polandcsd.org

Cc E-Mail:

Invoice To: **John D. Strickland**
Invoice E-Mail: jstrickland@polandcsd.org

Customer Project #: **02B15494**

Project Name:

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [] AK [] MT [] CT [] ET []

Regulatory Program (DW, RCRA, etc.) as applicable: **NY Lead in School DW**

[] Level II [] Level III [] Level IV

[] EQUIS

[] Other

Rush (Pre-approval required):
[] 2 Day [] 3 day [] 5 day [] Other

Date Results Requested:
Standard 30 business day

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [] Yes [] No

Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SD), Sludge (SL), Caulk

Customer Sample ID

Matrix *
DW

Comp / Grab
G

Collected (or Composite Start) Date Time

Composite End Date Time

Res. CL2

Number & Type of Containers Plastic Glass

200.8 Drinking Water (Pb only)

X

1

957

958

959

960

961

962

963

964

965

966

967

968

969

970

971

972

973

974

975

976

977

978

979

980

981

982

983

984

985

986

987

988

989

990

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Collected By:

Printed Name:

Signature:

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Relinquished by/Company (Signature)

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Additional Instructions from Pace®:

Coolers:

Thermostats/TC:

Correction Factor (°C):

Dr. Type (°C):

Corrected Temp (°C):

Tracking Number:

Delivered by: [] In-Person [] Courier

[] FedEx [] UPS [] Other

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Specify Container Size **

Identify Container Preservative Type ***

Analysis Requested

Proj. Mgr:

Accutum / Client ID:

Table #:

Profile / Template:

Prelog / Bottle Ord. ID:

Sample Comment

Preservation non-conformance identified for sample.

** Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other

*** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NH4SO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other



WO#: 70367053

PM: MC1 Due Date: 07/24/25

CLIENT: PolandCS

Client:

Work ID:

Profile #

COC Page

Use Point Number Spreadsheet

Add SCLOGFD to first sample for field charge

roject

Sender Initials

Additional Comments

W04#70367053

Page 24 of 26

26

Pacific Analytical Services, LLC

Page 1 of 1

Client:

Profile #:

Work ID:

COC Page

of

2

Use Point Number Spreadsheet

Multiday Project

Add SCLOGFD to first sample for field charge

COC Line Item	Materia
90C	
10C	
BGIN	
LTHG	
BGIN	
TEDL	
WFP	
GAN	
ZPLC	
WGDU	
WGKU	
WGFU	
WGZU	
R	
SP5T	
BP1B	
BP1N	
BP1Z	
BP3R	
BP3S	
BP3T	
BP3C	
BP2N	
BP3N	
BP4N	
BP2S	
BP3S	
BP1U	
BP2U	
BP3U	
BP4U	
WVG40	
WVG90	
CG1U	
AG44	
AG6U	
AG1A	
AG1H	
AG1T	
AG2R	
AG3T	
AG4E	
AG3S	
AG34	
AG1U	
AG2U	
AG3U	
AG4U	
DG9S	
DG6T	
DG9A	
DG9P	
DG9Y	
VG9T	
VG9S	
VG9H	
VG9C	
VG9U	

Container Codes

Codes	Glass	Plastic
WG9U	40mL unpres. clear vial	BP4U 125mL unpres. amber glass
WG9C	40mL HOI clear vial	BP3U 250mL unpres. amber glass
WG9H	40mL HOI clear vial	BP2U 250mL unpres. amber glass
WG9S	40mL Sulfuric clear vial	BP1U 500mL unpres. amber glass
WG9T	40mL Thiosulfate clear vial	BP4U 1L unpres. amber glass
WG9V	40mL Thiosulfate vial	BP2N 125mL HNO ₃ plastic
WG9W	40mL Curate-H ₂ O Tsp	BP3N 250mL HNO ₃ plastic
WG9X	40mL Curate-H ₂ O Tsp	BP2N 500mL HNO ₃ plastic
WG9A	Acetic/Maleic Acid 40mL	BP3S 250mL H ₂ SO ₄ plastic
WG8T	Na THO 60mL Vial	BP2S 250mL H ₂ SO ₄ plastic
WG9S	Ammonium Cl/CuSO ₄ 40mL	BP3C NaOH 250mL bottle
WG9G	1L Unpres. Jar (Con Ed)	BP3T 250mL Troma
WG9O	8oz clear soil jar	BP3S 250mL Ammonium Acetate
WG4Q	4oz clear soil jar	BP3R 250mL NH ₄ SO ₄ -NH ₄ OH
		BP1Z 1L NaOH, Zn Acetate
		BP1N 1L HNO ₃ plastic
		BP1H 1L Thiosulfate Amber Bottle

	Misc.
SP5T	120mL Collorm Na Thio
R	Terracore Kit
20Z	2oz Unpreserved Jar
WG2U	4oz Unpreserved Jar
WG4U	8oz Unpreserved Jar
WG6U	16oz Unpreserved Jar
WG8U	32oz Unpreserved Jar
WG10U	64oz Unpreserved Jar
WG12U	128oz Unpreserved Jar
WG14U	256oz Unpreserved Jar
WG16U	512oz Unpreserved Jar
WG18U	1024oz Unpreserved Jar
WG20U	2048oz Unpreserved Jar
WG22U	4096oz Unpreserved Jar
WG24U	8192oz Unpreserved Jar
WG26U	16384oz Unpreserved Jar
WG28U	32768oz Unpreserved Jar
WG30U	65536oz Unpreserved Jar
WG32U	131072oz Unpreserved Jar
WG34U	262144oz Unpreserved Jar
WG36U	524288oz Unpreserved Jar
WG38U	1048576oz Unpreserved Jar
WG40U	2097152oz Unpreserved Jar
WG42U	4194304oz Unpreserved Jar
WG44U	8388608oz Unpreserved Jar
WG46U	16777216oz Unpreserved Jar
WG48U	33554432oz Unpreserved Jar
WG50U	67108864oz Unpreserved Jar
WG52U	134217728oz Unpreserved Jar
WG54U	268435456oz Unpreserved Jar
WG56U	536870912oz Unpreserved Jar
WG58U	1073741824oz Unpreserved Jar
WG60U	2147483648oz Unpreserved Jar
WG62U	4294967296oz Unpreserved Jar
WG64U	8589934592oz Unpreserved Jar
WG66U	17179869184oz Unpreserved Jar
WG68U	34359738368oz Unpreserved Jar
WG70U	68719476736oz Unpreserved Jar
WG72U	137438953472oz Unpreserved Jar
WG74U	274877906944oz Unpreserved Jar
WG76U	549755813888oz Unpreserved Jar
WG78U	1099511627776oz Unpreserved Jar
WG80U	2199023255552oz Unpreserved Jar
WG82U	4398046511104oz Unpreserved Jar
WG84U	8796093022208oz Unpreserved Jar
WG86U	17592186044416oz Unpreserved Jar
WG88U	35184372088832oz Unpreserved Jar
WG90U	70368744177664oz Unpreserved Jar
WG92U	140737488355328oz Unpreserved Jar
WG94U	281474976710656oz Unpreserved Jar
WG96U	562949953421312oz Unpreserved Jar
WG98U	1125899906842624oz Unpreserved Jar
WG100U	2251799813685248oz Unpreserved Jar
WG102U	4503599627370496oz Unpreserved Jar
WG104U	9007199254740992oz Unpreserved Jar
WG106U	18014398509481984oz Unpreserved Jar
WG108U	36028797018963968oz Unpreserved Jar
WG110U	72057594037927936oz Unpreserved Jar
WG112U	144115188075855872oz Unpreserved Jar
WG114U	288230376151711744oz Unpreserved Jar
WG116U	576460752303423488oz Unpreserved Jar
WG118U	1152921504606846976oz Unpreserved Jar
WG120U	2305843009213693952oz Unpreserved Jar
WG122U	4611686018427387904oz Unpreserved Jar
WG124U	9223372036854775808oz Unpreserved Jar
WG126U	18446744073709551616oz Unpreserved Jar
WG128U	36893488147419103232oz Unpreserved Jar
WG130U	73786976294838206464oz Unpreserved Jar
WG132U	147573952589676412928oz Unpreserved Jar
WG134U	295147905179352825856oz Unpreserved Jar
WG136U	590295810358705651712oz Unpreserved Jar
WG138U	1180591620717411303424oz Unpreserved Jar
WG140U	2361183241434822606848oz Unpreserved Jar
WG142U	4722366482869645213696oz Unpreserved Jar
WG144U	9444732965739290427392oz Unpreserved Jar
WG146U	18889465931478580854784oz Unpreserved Jar
WG148U	37778931862957161709568oz Unpreserved Jar
WG150U	75557863725914323419136oz Unpreserved Jar
WG152U	151115727451828646838272oz Unpreserved Jar
WG154U	302231454903657293676544oz Unpreserved Jar
WG156U	604462909807314587353088oz Unpreserved Jar
WG158U	1208925819614629174706176oz Unpreserved Jar
WG160U	2417851639229258349412352oz Unpreserved Jar
WG162U	4835703278458516698824704oz Unpreserved Jar
WG164U	9671406556917033397649408oz Unpreserved Jar
WG166U	19342813113834066795298816oz Unpreserved Jar
WG168U	38685626227668133590597632oz Unpreserved Jar
WG170U	77371252455336267181195264oz Unpreserved Jar
WG172U	154742504910672534362390528oz Unpreserved Jar
WG174U	309485009821345068724781056oz Unpreserved Jar
WG176U	618970019642690137449562112oz Unpreserved Jar
WG178U	1237940039285380274899124224oz Unpreserved Jar
WG180U	2475880078570760549798248448oz Unpreserved Jar
WG182U	4951760157141521099596496896oz Unpreserved Jar
WG184U	9903520314283042199192993792oz Unpreserved Jar
WG186U	1980704062856608439838598784oz Unpreserved Jar
WG188U	3961408125713216879677197568oz Unpreserved Jar
WG190U	7922816251426433759354395136oz Unpreserved Jar
WG192U	15845632502852867518708790272oz Unpreserved Jar
WG194U	31691265005705735037417580544oz Unpreserved Jar
WG196U	633

IOC	
BP1U	1L unpreserved plastic
BP3N*	250mL HNO3 plastic
BP3C	250mL Sodium Hydroxide
AG2U	500mL unpres amber glass
BP3U	250mL unpreserved plastic

* Can also be a BP4N

Matrix	
WT	Water
SL	Solid
NAL	Non-aqueous Liquid
OL	Oil
WP	Wipe
DW	Drinking Water

SDC	
V93T	40mL Na Thio amber vial
DG9A	40mL Ascorbic acid malleic acid vials
DG9Y	Citrate/Na Thiosulfate 40mL
DG6T	Na Thiosulfate 60mL vial
DG8M	MonoClAcetic/Na Thio 60mL
AG3U	250mL unpres amber glass
AG3T	Na Thiosulfate 250mL bottle
BP1B	Na Thiosulfate Amber bottle
AG1T	Na Thiosulfate 1L Amber
AG1A	45L 2 Chamber Beaker

Sander Initials

Additional Comments

WO# 76362053

Client Name:

PolandCS

Project #

WO#: 70367053

PM: MC1

Due Date: 07/24/25

CLIENT: PolandCS

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other Type of Ice: Wet Blue None

Thermometer Used: TH211 Correction Factor: 6.2 ☐ Samples on ice, cooling process has begun

Cooler Temperature(°C): 19.5 Cooler Temperature Corrected(°C): 19.7 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ No

Did samples originate from a foreign source including Hawaii and Puerto Rico? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

	COMMENTS:
Chain of Custody Present: ☒ Yes ☐ No	1.
Chain of Custody Filled Out: ☒ Yes ☐ No	2.
Chain of Custody Relinquished: ☒ Yes ☐ No	3.
Sampler Name & Signature on COC: ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time: ☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr): ☐ Yes ☒ No	6.
Rush Turn Around Time Requested: ☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) ☒ Yes ☐ No	8.
Correct Containers Used: ☒ Yes ☐ No	9.
-Pace Containers Used: ☒ Yes ☐ No	
Containers Intact: ☒ Yes ☐ No	10.
Filtered volume received for Dissolved tests ☐ Yes ☐ No ☒ N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: ☒ Yes ☐ No	12.
-Includes date/time/ID/Analysis Matrix: SL ☒ OIL OTHER	

Date and Initials of person checking preservation:

All containers needing preservation have been ☒ Yes ☐ No ☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot # 231224	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, ☒ Yes ☐ No ☐ N/A NAOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	
Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: ☐ Yes ☐ No ☒ N/A	14.
KI starch test strips Lot #	Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sulf ☐ Yes ☐ No ☒ N/A	15.
Lead Acetate Strips Lot #	Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	
Headspace in VOA Vials (>6mm): ☐ Yes ☐ No ☒ N/A	16.
Trip Blank Present: ☐ Yes ☐ No ☒ N/A	
Trip Blank Custody Seals Present ☐ Yes ☐ No ☒ N/A	17.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.